

Cherry Valley-Springfield Central School

Lead in water exceedances for initial samples taken on 9/28/2016.

	Location/Sample ID	Lead level in parts per billion (action level 15 ppb)
1	116 concession	15.3
2	PSR prep sink right	19.6
3	253B staff rm sink	39.5
4	257A sink left	25.2
5	257D sink right	34.8

Sampling conducted by Rick Collins and Brandon Lundy

Analysis conducted by Microbac Laboratories